

IMPORTANT INFORMATION

Source of Drinking Water

Annual Drinking Water Quality Report

PECATONICA

IL2010250

Annual Water Quality Report for the period of January 1 to December 31, 2010

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by PECATONICA is Ground Water

For more information regarding this report contact:
Name Michael Stahler
Phone (815) 239-2348

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

Because the Village of Pecatonica Water Supply received a Method of Delivery Waiver and serves a direct population between 501 and 10,000, the CCR was not mailed to each customer. However, as required our CCR was published in its entirety in one or more newspapers (The Gazette), was also posted on the Village of Pecatonica web site (villageofpecatonica.com), and copies are available at the Village of Pecatonica office located at 405 Main Street, Pecatonica, IL 61063-0730

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pickup substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Source Water Information

| Source Water Name | Type of Water | Report Status | Location |
|-------------------|---------------|---------------|-------------------------------|
| WELL 1 (11618) | GW | Active | 100 E. 8 th Street |
| WELL 2 (11619) | GW | Active | 120 W. 7 th Street |

Source Water Assessment

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by Village Hall or call our water operator at (815) 239-2348. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

Based on information obtained in a Well Site Survey published in 1989 by the Illinois EPA, several potential sources are located within 1,000 feet of the well. The Illinois EPA has determined that the Pecatonica Community Water Supply's source water is not susceptible to contamination. This determination is based on a number of criteria including; monitoring conducted at the well; monitoring conducted at the entry point to the distribution system; and available hydro geologic data on the well.

Water Quality Test Results

| | |
|--|--|
| Maximum Contaminant Level Goal or MCLG: | The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. |
| Maximum Contaminant Level or MCL: | The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. |
| Maximum residual disinfectant level goal or MRDLG: | The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants. |
| Maximum residual disinfectant level or MRDL: | The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants. |
| Definitions: | The following tables contain scientific terms and measures, some of which may require explanation. |
| ppb: | micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water. |
| na: | not applicable. |
| Avg: | Regulatory compliance with some MCLs are based on running annual average of monthly samples. |
| ppm: | milligrams per liter or parts per million - or one ounce in 7,350 gallons of water. |

Regulated Contaminants

| Disinfectants and Disinfection By-Products | Collection Date | Highest Level Detected | Range of Levels Detected | MCLG | MCL | Units | Violation | Likely Source of Contamination |
|--|-----------------|------------------------|--------------------------|-----------------------|----------|-------|-----------|--|
| Chlorine | | 0.4 | 0.34 - 0.435 | MRDLG = 4 | MRDL = 4 | ppm | N | Water additive used to control microbes. |
| Total Trihalomethanes (TThm) * | | 1.2 | 1.2 - 1.2 | No goal for the total | 80 | ppb | N | By-product of drinking water chlorination. |
| Not all sample results may have been used for calculating the Highest Level Detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future | | | | | | | | |
| Inorganic Contaminants | Collection Date | Highest Level Detected | Range of Levels Detected | MCLG | MCL | Units | Violation | Likely Source of Contamination |
| Arsenic | 02/10/2009 | 0.51 | 0 - 0.51 | 0 | 10 | ppb | N | Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes. |
| Barium | 02/10/2009 | 0.231 | 0.229 - 0.231 | 2 | 2 | ppm | N | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits. |
| Fluoride | 02/10/2009 | 1.53 | 1.42 - 1.53 | 4 | 4.0 | ppm | N | Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories. |
| Iron | 02/10/2009 | 0.094 | 0.0934 - 0.094 | | 1.0 | ppm | N | This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits. |
| Nitrate [measured as Nitrogen] | | 2 | 1.41 - 1.56 | 10 | 10 | ppm | N | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits. |
| Sodium | 02/10/2009 | 4.43 | 4.38 - 4.43 | | | ppm | N | Erosion from naturally occurring deposits: Used in water softener regeneration. |
| Radioactive Contaminants | Collection Date | Highest Level Detected | Range of Levels Detected | MCLG | MCL | Units | Violation | Likely Source of Contamination |

| | | | | | | | | |
|------------------------------------|------------|-----|-----------|---|---|-------|---|------------------------------|
| Combined Radium 226/228 | 10/22/2008 | 2.2 | 2.2 - 2.2 | 0 | 5 | pCi/L | N | Erosion of natural deposits. |
|------------------------------------|------------|-----|-----------|---|---|-------|---|------------------------------|

| | | | | | | | | |
|--|------------|-----|-----------|---|----|-------|---|------------------------------|
| Gross alpha excluding radon and uranium | 10/22/2008 | 5.5 | 5.1 - 5.5 | 0 | 15 | pCi/L | N | Erosion of natural deposits. |
|--|------------|-----|-----------|---|----|-------|---|------------------------------|

| | | | | | | | | |
|----------------|------------|--------|-----------------|---|----|------|---|------------------------------|
| Uranium | 10/22/2008 | 0.5513 | 0.5513 - 0.5513 | 0 | 30 | ug/l | N | Erosion of natural deposits. |
|----------------|------------|--------|-----------------|---|----|------|---|------------------------------|
